

**Summary report of lightning protection risk assessment  
for Olympic stadium.**


REV.	DATE	DESCRIPTION	CHECKED	APPROVED
OR	24/04/15	Author		



Earthing - Lightning Protection - Height Safety

## Contents

- 1. Introduction
  - 1.1 Executive summary
  - 1.2 Project standards
    - 1.2.1 BS 6651:1999
    - 1.2.2 BS EN 62305:20011
  - 1.3 Other reference documents
    - 1.3.1 Drawing references
  
- 2. Risk management
  - 2.1 Introduction
    - 2.1.1  $R_1$  - risk of loss of human life
    - 2.1.2  $R_2$  - risk of loss of services to the public
    - 2.1.3  $R_3$  - risk of loss of cultural heritage
    - 2.1.4  $R_4$  - risk of loss of economic value
  
- 3. Detailed summary
  - 3.1 External lightning protection
  - 3.1.2 Internal lightning protection
  
- 4. Appendices
  - 4.1 Risk assessment summary
  - 4.2 Risk assessment for Olympic stadium

	<b>Lightning protection Report</b>	Revision: <b>OR</b>
---	------------------------------------	------------------------

## **1. Introduction**

Lightning flashes to, or nearby structures are hazardous to people, to the structures themselves, their contents and installations. The need for protection, the economic benefits of installing protection measures and the selection of adequate protection measures should be determined in terms of risk management.

### **1.1 Executive summary**

Risk assessments, in accordance with BS EN 62305 and as required by the project specification, were carried out by Omega Red Group Ltd for Imtech Engineering Services Central.

This study, only considered the R<sub>1</sub> risk category for the loss of human life as a result of damage to the structures. It does not consider the loss of services to the public (R<sub>2</sub> risk category) or any subsequent consequential financial losses as a result. Thus being as the most important factor to consider is the loss of human life.

The resulting overview is that a lightning protection system (catenary system) is not required, however a level 3 lightning protection to the stadium itself will be required.

There have been 2no risk assessments issued, one risk assessment showing the tolerable risk with no lightning protection applied to the structure and one risk assessment showing the structure with a level 3 lightning protection system. The risk of the pitch taking a direct strike without protection is 1 in 31,900,000 chance, this figure has been generated from a risk assessment carried out by myself in which it has indicated without protection the figure of 3.19E-07 (31,900,000).

### **1.2 Project standards**

#### **1.2.1 BS 6651:1999**


BS 6651:1999, where it relates to the installation of lightning protection systems to new structures and new extensions to existing structures, was withdrawn on 31<sup>st</sup> August 2008.

#### **1.2.2 BS EN 62305:2011**

BS EN 62305:2011 is the latest reference document for the protection against lightning. It replaced BS 6651:1999 from 1<sup>st</sup> September 2008. It is the British edition of the European standard to which all lightning protection systems to new structures, and new extensions to existing ones, are now designed, installed and maintained. BS EN 62305:2011 comprises four parts and these detail the fundamental requirements for lightning protection systems for the external and internal parts of a structure. The four parts are as follows:

- Part 1: General principles
- Part 2: Risk management
- Part 3: Physical damage to structures and life hazard
- Part 4: Electrical and electronic systems within buildings.



	<b>Lightning protection Report</b>	Revision: OR
---	------------------------------------	-----------------

BS EN 62305-1:2011 provides the general principles to be followed in the protection against lightning of structures, including their installations and contents as well as persons.

BS EN 62305-2:2011 is applicable to risk assessment for a structure due to lightning flashes. Its purpose is to provide a procedure for the evaluation of such a risk.

BS EN 62305-3:2011 provides the requirements for protection of a structure against physical damage by means of a lightning protection system (LPS), and for protection against injury to living beings due to touch and step voltages in the vicinity of an LPS.

BS EN 62305-4:2011 provides information for the design, installation and maintenance of lightning electromagnetic impulse (LEMP) protection measures system for electrical and electronic systems within structures, able to reduce the risk of permanent failures due to LEMP.


### 1.3 Other reference documents & drawings

The following is a brief and not exhaustive list of reference documents relevant to this project:

- BS EN62305:2011 - Protection against Lightning
- A Guide to BS EN62305:2006, Protection against Lightning 2nd Edition, Furse.
- Protection against Lightning Protection, A guide to the practical application of BS EN62305:2006.

#### 1.3.1 Drawing references

- LC201-STA-STA-S-DGA-1400, LC201-STA-SCN-A-DSE-0062, LC201-STA-ROF-A-DGA-1026, LC201-STA-ROF-A-DGA-1016, LC201-STA-ROF-A-DGA-3000, LC201-STA-ROF-A-DGA-7016, LC201-STA-ROF-A-DGA-7017, LC201-STA-SCN-A-DSE-0062, LC201-STA-STA-S-DGA-1400, LC201-STA-STA-S-DGA-1430, LC201-STA-STA-S-DGA-1440, LC201-STA-ROF-A-DGA-0040, LC201-STA-ROF-A-DGA-0041, LC201-STA-ROF-A-DGA-0042, LC201-STA-ROF-A-DGA-0043, LC201-STA-ROF-A-DGA-0055, LC201-STA-ROF-A-DGA-3008, LC201-STA-ROF-A-DGA-7018, LC201-STA-ROF-A-DGA-7019, LC201-STA-ROF-E-DGA-0033, LC201-STA-STA-S-DGA-1400, LC201-STA-STA-S-DGA-1422, LC201-STA-STA-S-DGA-1431, LC201-STA-STA-S-DGA-1461, LC201-STA-STA-S-DGA-1440, LC201-STA-STA-S-DGA-1430, LC201-STA-STA-S-DGA-1421, LC201-STA-STA-S-DGA-4803, LC201-STA-STA-S-DGA-1423, LC201-STA-STA-S-DGA-1442.

	<b>Lightning protection Report</b>	Revision: OR
---	------------------------------------	-----------------

## 2. Risk management

### 2.1 Introduction

Undertaking a risk assessment is the basis for determining whether or not lightning protection measures are required, as described in BS EN 62305-2:2006. Protection against lightning is required if the risk  $R_n$  (whether this be  $R_1$ ,  $R_2$  or  $R_3$ ) is greater than the tolerable (acceptable) risk  $R_T$ . Conversely, if the risk  $R_n$  is lower than  $R_T$  then protection measures are not required. The values of tolerable risk  $R_T$  considered are as those detailed (for the UK) in BS EN 62305-2:2006 Annex NK. Below is a brief description of each primary risk category.

#### 2.1.1 $R_1$ - risk of loss of human life

This is self explanatory, is the most important risk and is considered in all cases.

#### 2.1.2 $R_2$ - risk of loss of services to the public

This is the loss that can occur when a service provider (eg London Underground) cannot provide its service to its customers, due to lightning inflicted damage. There is also the subsequent risk of consequential financial loss to consider.

#### 2.1.3 $R_3$ - risk of loss of cultural heritage

Again this is fairly self explanatory, where the loss of a historically important structure would be disastrous. This risk is not considered on this occasion.

#### 2.1.4 $R_4$ - risk of loss of economic value

There is no tolerable risk value for  $R_4$ . Evaluating such a risk is a tortuous process, especially when the figures required are not readily available. This risk is not considered on this occasion.

### 3. Detailed summary

#### 3.1 External Lighting Protection

External lightning protection is required on the stadium structure, and a lightning protection system is not required for the pitch, as without protection (catenary wire) the pitch is under the tolerable risk.

##### 3.1.2 Internal Lighting Protection

Internal lightning protection system will only apply to the stadium building it does not need to be considered for the protection for the pitch.

### 4. Appendices

#### 4.1 Risk assessment summary

##### Terminology used in BS EN 62305-2:2006 Risk Management Calculations

Case name: is the structure to be protected  
Date: is the date the risk assessment is carried out

##### Primary risk totals

$R_T$  tolerable risk is the maximum value of the risk, which can be tolerated for the structure, in each risk category ( $R_1, R_2, R_3, R_4$ )

##### Protection system design parameters

LPS 1, 2, 3, 4 or none is the level (class) of lightning protection system  
ISPD value in kA is the maximum peak current rating for lightning current SPDs  
Lines are the typical services entering the primary structure (possibly from a secondary structure) and connecting to electrical and electronic equipment within the structure

##### Environment

$N_g$  factor is the flash density in strikes to ground per kilometre square per year (e.g. thunderstorm days per year)  
 $C_d$  factor is the location of the structure relative to its surroundings  
 $C_e$  factor is the service line density in the vicinity of the structure  
 $Rho$  value in  $\Omega m$  is the soil resistivity of the ground around the structure

##### Primary structure

is the structure to be protected, including a description of its overall shape and roof type  
 $L_b$  value in M is the length of the structure  
 $W_b$  value in M is the width of the structure  
 $H_e$  value in M is the height to the eaves of the roof of the structure  
 $H_r$  value in M is the height to the ridge of the roof of the structure  
 $H_b$  value in M is the height of the structure with a flat roof

**Lines** are the typical services entering the primary structure (possibly from a secondary structure) and connecting to electrical and electronic equipment within the structure

**Zones** are the defined lightning protection zones for the structure

**Please note:** There can be many individual factors in the make-up of each of the items described above and as detailed in the risk assessment summaries below. This is a brief summary list. It is not practical to describe all of these in this report.

#### 4.1.2 Olympic stadium

##### BS EN 62305-2:2006 Risk Management Calculations

Case name: Olympic stadium  
Date: 24<sup>th</sup> April 2015

##### Primary risk totals

<b>R1_T</b>	5.1938E-06	Risk of loss of human life in the structure The tolerable risk is not exceeded, no additional protection required
<b>R2_T</b>	0.E00	Risk of loss of service to the public in the structure The tolerable risk is not exceeded, no additional protection required
<b>R3_T</b>	0.E00	Risk of loss of cultural heritage in the structure This risk has not been determined
<b>R4_T</b>	0.E00	Risk of loss of economic value in the structure This risk has not been determined

##### Protection system design parameters

<b>LPS</b>	Class III	
<b>ISPD</b>	25.00kA	Maximum peak current of equipotential bonding SPDs for each of 'n' lines defined.
<b>Line 1 -</b>		Protect Line 1 at its entrance to the structure with a standard equipotential bonding SPD (rated to ISPD above) in accordance with BS EN 62305-3
<b>Line 2 -</b>		Protect Line 2 at its entrance to the structure with a standard equipotential bonding SPD (rated to ISPD above) in accordance with BS EN 62305-3.

Note: protect incoming supplies with Type 1 SPDs (mains 12.5kA 10/350µs, data/telecom 2.5 kA 10/350µs), protect underground lines with Type 2 SPDs (tested with an 8/20µs waveform)

Protect all internal systems connected to Line 1 with a coordinated set of standard SPDs in accordance with BS EN 62305-4

**Environment**

<i>Ng</i>	0.70	Lightning flash density (Flashes/km <sup>2</sup> /year)
<i>Cd</i>	0.50	Location factor
<i>Ce</i>	0.00	Environmental factor
<i>Rho</i>	500.00Ωm	Soil resistivity (Ohm metres)

**Primary Structure**

		Olympic stadium - cylindrical
<i>Db</i>	327.00m	Diameter of primary structure.
<i>Hb</i>	25.00m	Height of primary structure.

**Lines**

Line 1	Power
Line 2	Telecoms

<b>Zones</b>	Zone 1	Internal
--------------	--------	----------



## BS EN 62305-2:2006 Risk Management Calculations

### Project details

Project name: New Project  
 Project title:  
 Project address:  
 Project ref:  
 Calculation ref:  
 Calculation notes:  
 Project author:  
 Created: 24 April 2015  
 Modified: 24 April 2015

### Case details

Case name: Olympic Stadium  
 Case title:  
 Created: 10 May 2013  
 Modified: 10 May 2013  
 Case notes:

### Primary risk totals

$R_{1\_T}$	5.1938E-06	Risk of loss of human life in the structure The tolerable risk is not exceeded, no additional protection required
$R_{2\_T}$	0.E00	Risk of loss of service to the public in the structure This risk has not been determined
$R_{3\_T}$	0.E00	Risk of loss of cultural heritage in the structure This risk has not been determined
$R_{4\_T}$	0.E00	Risk of loss of economic value in the structure This risk has not been determined

**Protection system design parameters**

LPS	LPL III	Protect the structure with a Class LPL III Lightning Protection System in accordance with BS EN 62305-3
I <sub>max</sub>	100.00kA	Maximum peak current
	97.00%	Probability that lightning current parameters are smaller than the maximum value defined above
I <sub>min</sub>	10.00kA	Minimum peak current
	91.00%	Probability that lightning current parameters are greater than the minimum value defined above
	45.00m	Radius of rolling sphere
ISPD	25.00kA	Maximum peak current of equipotential bonding SPD's for each of 'n' lines defined (based upon simple current division concept)  NOTE: The worst case surge that could be expected on a two-wire telephone or data line is 2.5kA (10/350 µs) per line (Category D test to BS EN 61643-21) to earth or 5 kA (10/350 µs) per pair.
Line 1		Protect Line 1 at its entrance to the structure with a standard equipotential bonding SPD (rated to ISPD above) in accordance with BS EN 62305-3  NOTE: Where SPDs are required but an LPS is not (ISPD = 0), protect overhead lines with Type 1 SPDs (mains 12.5kA 10/350µs, data/telecom 2.5kA 10/350µs), protect underground lines with overvoltage or Type 2 SPDs (tested with an 8/20 µs waveform)
Line 2		Protect Line 2 at its entrance to the structure with a standard equipotential bonding SPD (rated to ISPD above) in accordance with BS EN 62305-3  NOTE: Where SPDs are required but an LPS is not (ISPD = 0), protect overhead lines with Type 1 SPDs (mains 12.5kA 10/350µs, data/telecom 2.5kA 10/350µs), protect underground lines with overvoltage or Type 2 SPDs (tested with an 8/20 µs waveform)

**Environment**

N <sub>g</sub>	0.70	Lightning flash density (Flashes/km <sup>2</sup> /year)
C <sub>d</sub>	0.50	Location factor
C <sub>e</sub>	0.00	Environmental factor
Rho	500.00 Ωm	Soil resistivity (Ohm metres)

**Assessment of  $A_x$  - Collection areas (BS EN 62305-2 Annex A.2)**

$A_{d/b}$	178,700.86 m <sup>2</sup>	Collection area of primary structure
$A_{d/a}$ (2)	459.47 m <sup>2</sup>	Collection area of structure 2 (adjacent)
$A_{d/a}$ (3)	4,129.56 m <sup>2</sup>	Collection area of structure 3 (adjacent)
$A_m$	537,156.58 m <sup>2</sup>	Collection area of surrounding ground
$A_l$ (L1)	20,482.38 m <sup>2</sup>	Collection area of flashes striking line 1
$A_l$ (L2)	20,146.97 m <sup>2</sup>	Collection area of flashes striking line 2
$A_l$	40,629.36 m <sup>2</sup>	Total collection area of flashes striking lines
$A_i$ (L1)	559,016.99 m <sup>2</sup>	Collection area of flashes near line 1
$A_i$ (L2)	559,016.99 m <sup>2</sup>	Collection area of flashes near line 2
$A_i$	1,118,033.99 m <sup>2</sup>	Total collection area of flashes near lines

**Structures****Primary structure**

Structure ID: Olympic Stadium - Cylindrical

$D_b$	327.00 m	Diameter of primary structure
$H_b$	25.00 m	Height of primary structure

**Secondary structures**

Structure No Substation - Rectangular with a flat roof

$C_{da}$	0.25	Location factor for structure 2 (adjacent)
$L_a$	5.00 m	Length of secondary structure
$W_a$	5.00 m	Width of secondary structure
$H_a$	3.00 m	Height of secondary structure

Structure No Telephone Exchange - Rectangular with a flat roof

$C_{da}$	0.25	Location factor for structure 3 (adjacent)
$L_a$	20.00 m	Length of secondary structure
$W_a$	20.00 m	Width of secondary structure
$H_a$	8.00 m	Height of secondary structure

**Lines**

Line 1	Powercable	
$K_{S3}$ (L1)	1.00	Factor relevant to the characteristics of internal wiring for line 1
$P_{SPD}$ (L1)	0.03	Probability of failure of internal systems or a service when SPDs are provided for equipotential bonding (in accordance with BS EN 62305-3) for line 1
$P_{SPDc}$ (L1)	1.00	Probability of failure of internal systems or a service when coordinated SPDs are provided (in accordance with BS EN 62305-4) for line 1
$C_t$ (L1)	1.00	Correction factor for a hv/lv transformer on line 1
$C_{dc}$ (L1)	0.25	Location factor for line 1
$U_w$ (L1)	1.50 kV	Rated impulse withstand voltage of a system connected to line 1
$L_c$ (L1)	1,000.00 m	Length of line 1
$H_c$ (L1)	0.00 m	Height of the conductors above ground for line 1
Line 2	Telecoms	
$K_{S3}$ (L2)	1.00	Factor relevant to the characteristics of internal wiring for line 2
$P_{SPD}$ (L2)	0.03	Probability of failure of internal systems or a service when SPDs are provided for equipotential bonding (in accordance with BS EN 62305-3) for line 2
$P_{SPDc}$ (L2)	1.00	Probability of failure of internal systems or a service when coordinated SPDs are provided (in accordance with BS EN 62305-4) for line 2
$C_t$ (L2)	1.00	Correction factor for a hv/lv transformer on line 2
$C_{dc}$ (L2)	0.25	Location factor for line 2
$U_w$ (L2)	1.50 kV	Rated impulse withstand voltage of a system connected to line 2
$L_c$ (L2)	1,000.00 m	Length of line 2
$H_c$ (L2)	0.00 m	Height of the conductors above ground for line 2

**Zones**

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$r_p$	2.0E-01									
$r_f$	1.0E-02									
$r_a / r_u$	1.0E-02									
$h_{z1}$	10									
$h_{z4}$	1									
$L_{t1}$	1.0E-04									
$L_{f1}$	4.0E-02									
$L_{o1}$	0.0E00									
$L_{f2}$	0.0E00									
$L_{o2}$	0.0E00									
$L_{f3}$	0.0E00									
$L_{t4}$	0.0E00									
$L_{f4}$	0.0E00									
$L_{o4}$	0.0E00									

**Assessment of  $N_x$  - Annual number of dangerous events (BS EN 62305-2 Annex A)**

$N_{d/b}$	0.062545	Average number of flashes to main structure
$N_{d/a(2)}$	0.000080	Average number of flashes to structure 2 (adjacent)
$N_{d/a(3)}$	0.000723	Average number of flashes to structure 3 (adjacent)
$N_m$	0.313464	Average number of flashes to surrounding ground
$N_i(L1)$	0.003584	Average number of flashes to line 1
$N_i(L2)$	0.003526	Average number of flashes to line 2
$N_i(L1)$	0.000000	Average number of flashes near line 1
$N_i(L2)$	0.000000	Average number of flashes near line 2

**Assessment of  $P_x$  - Probability of damage for a structure (BS EN 62305-2 Annex NB)**

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$P_A$	1									
$P_B$	0.1									
$P_C(L1)$	1									
$P_C(L2)$	1									
$P_C$	1									
$K_{S1}$	0.25									
$K_{S2}$	1									
$K_{S4}(L1)$	1									
$K_{S4}(L2)$	1									
$K_{MS}(L1)$	2.5E-01									
$K_{MS}(L2)$	2.5E-01									
$P_{MS}(L1)$	9.4E-01									
$P_{MS}(L2)$	9.4E-01									
$P_M(L1)$	9.4E-01									
$P_M(L2)$	9.4E-01									
$P_M$	9.964E-01									
$P_{LD}(L1)$	1.0E00									
$P_{LD}(L2)$	1.0E00									
$P_{LI}(L1)$	1.0E00									
$P_{LI}(L2)$	1.0E00									
$P_U(L1)$	3.0E-02									
$P_U(L2)$	3.0E-02									
$P_V(L1)$	3.0E-02									
$P_V(L2)$	3.0E-02									
$P_W(L1)$	1.0E00									
$P_W(L2)$	1.0E00									
$P_Z(L1)$	1.0E00									
$P_Z(L2)$	1.0E00									

**Assessment of  $L_x$  - Amount of loss for a structure (BS EN 62305-2 Annex NC)****Loss factors relevant to  $R_1$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_A$	1.0E-06									
$L_B$	8.0E-04									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_U$	1.0E-06									
$L_V$	8.0E-04									
$L_W$	0.0E00									
$L_Z$	0.0E00									

**Loss factors relevant to  $R_2$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_B$	0.0E00									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_V$	0.0E00									
$L_W$	0.0E00									
$L_Z$	0.0E00									

**Loss factors relevant to  $R_3$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_B$	0.0E00									
$L_V$	0.0E00									

**Loss factors relevant to  $R_4$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_A$	0.0E00									
$L_B$	0.0E00									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_U$	0.0E00									
$L_V$	0.0E00									
$L_W$	0.0E00									
$L_Z$	0.0E00									

**Assessment of  $R_x$  - Risk components****Risk components relevant to  $R_1$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_A$	0.0E00									
$R_B$	5.0036E-06									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_U$ (L1)	1.0994E-10									
$R_U$ (L2)	1.2745E-10									
$R_V$ (L1)	8.7956E-08									
$R_V$ (L2)	1.0196E-07									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									
$R_Z$ (L2)	0.0E00									

**Risk components relevant to  $R_2$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_B$	0.0E00									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									
$R_Z$ (L2)	0.0E00									

**Risk components relevant to  $R_3$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_B$	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									



**Risk components relevant to  $R_4$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_A$	0.0E00									
$R_B$	0.0E00									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_U$ (L1)	0.0E00									
$R_U$ (L2)	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									

**Primary risk totals**

$R_{1\_T}$	5.1938E-06	Risk of loss of human life in the structure
$R_{2\_T}$	0.E00	Risk of loss of service to the public in the structure
$R_{3\_T}$	0.E00	Risk of loss of cultural heritage in the structure
$R_{4\_T}$	0.E00	Risk of loss of economic value in the structure

**Primary risk with respect to source of damage**

$R_{1\_D}$	5.0036E-06	Risk of loss of human life in the structure due to flashes to the structure (S1)
$R_{2\_D}$	0.E00	Risk of loss of service to the public in the structure due to flashes to the structure (S1)
$R_{3\_D}$	0.E00	Risk of loss of cultural heritage in the structure due to flashes to the structure (S1)
$R_{4\_D}$	0.E00	Risk of loss of economic value in the structure due to flashes to the structure (S1)
$R_{1\_I}$	1.9015E-07	Risk of loss of human life in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{2\_I}$	0.E00	Risk of loss of service to the public in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{3\_I}$	0.E00	Risk of loss of cultural heritage in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{4\_I}$	0.E00	Risk of loss of economic value in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)

**Primary risk with respect to type of damage**

<i>R1_S</i>	2.374E-10	Risk of loss of human life in the structure due to injury to living beings (D1)
<i>R2_S</i>	0.E00	Risk of loss of service to the public in the structure due to injury to living beings (D1)
<i>R3_S</i>	0.E00	Risk of loss of cultural heritage in the structure due to injury to living beings (D1)
<i>R4_S</i>	0.E00	Risk of loss of economic value in the structure due to injury to living beings (D1)
<i>R1_F</i>	5.1935E-06	Risk of loss of human life in the structure due to physical damage (D2)
<i>R2_F</i>	0.E00	Risk of loss of service to the public in the structure due to physical damage (D2)
<i>R3_F</i>	5.1935E-06	Risk of loss of cultural heritage in the structure due to physical damage (D2)
<i>R4_F</i>	0.E00	Risk of loss of economic value in the structure due to physical damage (D2)
<i>R1_O</i>	0.E00	Risk of loss of human life in the structure due to failure of internal systems (D3)
<i>R2_O</i>	0.E00	Risk of loss of service to the public in the structure due to failure of internal systems (D3)
<i>R3_O</i>	0.E00	Risk of loss of cultural heritage in the structure due to failure of internal systems (D3)
<i>R4_O</i>	0.E00	Risk of loss of economic value in the structure due to failure of internal systems (D3)

## BS EN 62305-2:2006 Risk Management Calculations

### Project details

Project name: New Project  
 Project title:  
 Project address:  
 Project ref:  
 Calculation ref:  
 Calculation notes:  
 Project author:  
 Created: 24 April 2015  
 Modified: 24 April 2015

### Case details

Case name: Olympic Stadium  
 Case title:  
 Created: 10 May 2013  
 Modified: 10 May 2013  
 Case notes:

### Primary risk totals

$R_{1\_T}$	5.6375E-05	Risk of loss of human life in the structure The tolerable risk is exceeded, therefore protection measures must be instigated
$R_{2\_T}$	0.E00	Risk of loss of service to the public in the structure This risk has not been determined
$R_{3\_T}$	0.E00	Risk of loss of cultural heritage in the structure This risk has not been determined
$R_{4\_T}$	0.E00	Risk of loss of economic value in the structure This risk has not been determined

## Protection system design parameters

LPS	None	
ISPD	0.00kA	Maximum peak current of equipotential bonding SPD's for each of 'n' lines defined (based upon simple current division concept)
		NOTE: The worst case surge that could be expected on a two-wire telephone or data line is 2.5kA (10/350 $\mu$ s) per line (Category D test to BS EN 61643-21) to earth or 5 kA (10/350 $\mu$ s) per pair.

## Environment

$N_g$	0.70	Lightning flash density (Flashes/km <sup>2</sup> /year)
$C_d$	0.50	Location factor
$C_e$	0.00	Environmental factor
Rho	500.00 $\Omega$ m	Soil resistivity (Ohm metres)

## Assessment of $A_x$ - Collection areas (BS EN 62305-2 Annex A.2)

$A_{d/b}$	178,700.86 m <sup>2</sup>	Collection area of primary structure
$A_{d/a}$ (2)	459.47 m <sup>2</sup>	Collection area of structure 2 (adjacent)
$A_{d/a}$ (3)	4,129.56 m <sup>2</sup>	Collection area of structure 3 (adjacent)
$A_m$	537,156.58 m <sup>2</sup>	Collection area of surrounding ground
$A_l$ (L1)	20,482.38 m <sup>2</sup>	Collection area of flashes striking line 1
$A_l$ (L2)	20,146.97 m <sup>2</sup>	Collection area of flashes striking line 2
$A_l$	40,629.36 m <sup>2</sup>	Total collection area of flashes striking lines
$A_i$ (L1)	559,016.99 m <sup>2</sup>	Collection area of flashes near line 1
$A_i$ (L2)	559,016.99 m <sup>2</sup>	Collection area of flashes near line 2
$A_i$	1,118,033.99 m <sup>2</sup>	Total collection area of flashes near lines

## Structures

### Primary structure

Structure ID:	Olympic Stadium - Cylindrical	
$D_b$	327.00 m	Diameter of primary structure
$H_b$	25.00 m	Height of primary structure

**Secondary structures**

Structure No	Substation - Rectangular with a flat roof	
$C_{da}$	0.25	Location factor for structure 2 (adjacent)
$L_a$	5.00 m	Length of secondary structure
$W_a$	5.00 m	Width of secondary structure
$H_a$	3.00 m	Height of secondary structure

Structure No	Telephone Exchange - Rectangular with a flat roof	
$C_{da}$	0.25	Location factor for structure 3 (adjacent)
$L_a$	20.00 m	Length of secondary structure
$W_a$	20.00 m	Width of secondary structure
$H_a$	8.00 m	Height of secondary structure

**Lines**

Line 1	Powercable	
$K_{S3}$ (L1)	1.00	Factor relevant to the characteristics of internal wiring for line 1
$P_{SPD}$ (L1)	1.00	Probability of failure of internal systems or a service when SPDs are provided for equipotential bonding (in accordance with BS EN 62305-3) for line 1
$P_{SPDc}$ (L1)	1.00	Probability of failure of internal systems or a service when coordinated SPDs are provided (in accordance with BS EN 62305-4) for line 1
$C_t$ (L1)	1.00	Correction factor for a hv/lv transformer on line 1
$C_{dc}$ (L1)	0.25	Location factor for line 1
$U_w$ (L1)	1.50 kV	Rated impulse withstand voltage of a system connected to line 1
$L_c$ (L1)	1,000.00 m	Length of line 1
$H_c$ (L1)	0.00 m	Height of the conductors above ground for line 1
Line 2	Telecoms	
$K_{S3}$ (L2)	1.00	Factor relevant to the characteristics of internal wiring for line 2
$P_{SPD}$ (L2)	1.00	Probability of failure of internal systems or a service when SPDs are provided for equipotential bonding (in accordance with BS EN 62305-3) for line 2
$P_{SPDc}$ (L2)	1.00	Probability of failure of internal systems or a service when coordinated SPDs are provided (in accordance with BS EN 62305-4) for line 2
$C_t$ (L2)	1.00	Correction factor for a hv/lv transformer on line 2
$C_{dc}$ (L2)	0.25	Location factor for line 2
$U_w$ (L2)	1.50 kV	Rated impulse withstand voltage of a system connected to line 2
$L_c$ (L2)	1,000.00 m	Length of line 2
$H_c$ (L2)	0.00 m	Height of the conductors above ground for line 2

**Zones**

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$r_p$	2.0E-01									
$r_f$	1.0E-02									
$r_a / r_u$	1.0E-02									
$h_{z1}$	10									
$h_{z4}$	1									
$L_{t1}$	1.0E-04									
$L_{f1}$	4.0E-02									
$L_{o1}$	0.0E00									
$L_{f2}$	0.0E00									
$L_{o2}$	0.0E00									
$L_{f3}$	0.0E00									
$L_{t4}$	0.0E00									
$L_{f4}$	0.0E00									
$L_{o4}$	0.0E00									

**Assessment of  $N_x$  - Annual number of dangerous events (BS EN 62305-2 Annex A)**

$N_{d/b}$	0.062545	Average number of flashes to main structure
$N_{d/a (2)}$	0.000080	Average number of flashes to structure 2 (adjacent)
$N_{d/a (3)}$	0.000723	Average number of flashes to structure 3 (adjacent)
$N_m$	0.313464	Average number of flashes to surrounding ground
$N_i (L1)$	0.003584	Average number of flashes to line 1
$N_i (L2)$	0.003526	Average number of flashes to line 2
$N_i (L1)$	0.000000	Average number of flashes near line 1
$N_i (L2)$	0.000000	Average number of flashes near line 2

**Assessment of  $P_x$  - Probability of damage for a structure (BS EN 62305-2 Annex NB)**

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$P_A$	1									
$P_B$	1									
$P_C(L1)$	1									
$P_C(L2)$	1									
$P_C$	1									
$K_{S1}$	0.25									
$K_{S2}$	1									
$K_{S4}(L1)$	1									
$K_{S4}(L2)$	1									
$K_{MS}(L1)$	2.5E-01									
$K_{MS}(L2)$	2.5E-01									
$P_{MS}(L1)$	9.4E-01									
$P_{MS}(L2)$	9.4E-01									
$P_M(L1)$	9.4E-01									
$P_M(L2)$	9.4E-01									
$P_M$	9.964E-01									
$P_{LD}(L1)$	1.0E00									
$P_{LD}(L2)$	1.0E00									
$P_{LI}(L1)$	1.0E00									
$P_{LI}(L2)$	1.0E00									
$P_U(L1)$	1.0E00									
$P_U(L2)$	1.0E00									
$P_V(L1)$	1.0E00									
$P_V(L2)$	1.0E00									
$P_W(L1)$	1.0E00									
$P_W(L2)$	1.0E00									
$P_Z(L1)$	1.0E00									
$P_Z(L2)$	1.0E00									

**Assessment of  $L_x$  - Amount of loss for a structure (BS EN 62305-2 Annex NC)****Loss factors relevant to  $R_1$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_A$	1.0E-06									
$L_B$	8.0E-04									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_U$	1.0E-06									
$L_V$	8.0E-04									
$L_W$	0.0E00									
$L_Z$	0.0E00									

**Loss factors relevant to  $R_2$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_B$	0.0E00									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_V$	0.0E00									
$L_W$	0.0E00									
$L_Z$	0.0E00									

**Loss factors relevant to  $R_3$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_B$	0.0E00									
$L_V$	0.0E00									

**Loss factors relevant to  $R_4$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$L_A$	0.0E00									
$L_B$	0.0E00									
$L_C$	0.0E00									
$L_M$	0.0E00									
$L_U$	0.0E00									
$L_V$	0.0E00									
$L_W$	0.0E00									
$L_Z$	0.0E00									



**Assessment of  $R_x$  - Risk components****Risk components relevant to  $R_1$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_A$	0.0E00									
$R_B$	5.0036E-05									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_U$ (L1)	3.6648E-09									
$R_U$ (L2)	4.2484E-09									
$R_V$ (L1)	2.9319E-06									
$R_V$ (L2)	3.3987E-06									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									
$R_Z$ (L2)	0.0E00									

**Risk components relevant to  $R_2$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_B$	0.0E00									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									
$R_Z$ (L2)	0.0E00									

**Risk components relevant to  $R_3$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_B$	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									

**Risk components relevant to  $R_4$** 

Factor	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Zone 9	Zone 10
$R_A$	0.0E00									
$R_B$	0.0E00									
$R_C$	0.0E00									
$R_M$	0.0E00									
$R_U$ (L1)	0.0E00									
$R_U$ (L2)	0.0E00									
$R_V$ (L1)	0.0E00									
$R_V$ (L2)	0.0E00									
$R_W$ (L1)	0.0E00									
$R_W$ (L2)	0.0E00									
$R_Z$ (L1)	0.0E00									
$R_Z$ (L2)	0.0E00									

**Primary risk totals**

$R_{1\_T}$	5.6375E-05	Risk of loss of human life in the structure
$R_{2\_T}$	0.E00	Risk of loss of service to the public in the structure
$R_{3\_T}$	0.E00	Risk of loss of cultural heritage in the structure
$R_{4\_T}$	0.E00	Risk of loss of economic value in the structure

**Primary risk with respect to source of damage**

$R_{1\_D}$	5.0036E-05	Risk of loss of human life in the structure due to flashes to the structure (S1)
$R_{2\_D}$	0.E00	Risk of loss of service to the public in the structure due to flashes to the structure (S1)
$R_{3\_D}$	0.E00	Risk of loss of cultural heritage in the structure due to flashes to the structure (S1)
$R_{4\_D}$	0.E00	Risk of loss of economic value in the structure due to flashes to the structure (S1)
$R_{1\_I}$	6.3385E-06	Risk of loss of human life in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{2\_I}$	0.E00	Risk of loss of service to the public in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{3\_I}$	0.E00	Risk of loss of cultural heritage in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)
$R_{4\_I}$	0.E00	Risk of loss of economic value in the structure due to flashes influencing, but not striking the structure (S2, S3, S4)

**Primary risk with respect to type of damage**

<i>R1_S</i>	7.9132E-09	Risk of loss of human life in the structure due to injury to living beings (D1)
<i>R2_S</i>	0.E00	Risk of loss of service to the public in the structure due to injury to living beings (D1)
<i>R3_S</i>	0.E00	Risk of loss of cultural heritage in the structure due to injury to living beings (D1)
<i>R4_S</i>	0.E00	Risk of loss of economic value in the structure due to injury to living beings (D1)
<i>R1_F</i>	5.6367E-05	Risk of loss of human life in the structure due to physical damage (D2)
<i>R2_F</i>	0.E00	Risk of loss of service to the public in the structure due to physical damage (D2)
<i>R3_F</i>	5.6367E-05	Risk of loss of cultural heritage in the structure due to physical damage (D2)
<i>R4_F</i>	0.E00	Risk of loss of economic value in the structure due to physical damage (D2)
<i>R1_O</i>	0.E00	Risk of loss of human life in the structure due to failure of internal systems (D3)
<i>R2_O</i>	0.E00	Risk of loss of service to the public in the structure due to failure of internal systems (D3)
<i>R3_O</i>	0.E00	Risk of loss of cultural heritage in the structure due to failure of internal systems (D3)
<i>R4_O</i>	0.E00	Risk of loss of economic value in the structure due to failure of internal systems (D3)